

Smart, Mark

From: Sabre Strout <sstrout@nycoa.com>
Sent: Wednesday, February 19, 2020 10:50 AM
To: STEPHANIE.LARSON@DES.NH.GOV; Pastrana-Del Valle, Solanch
Subject: NPDES NH0000116 Non-contact Cooling Water pH Exceedance
Attachments: ATT00001.txt

Categories: EZ Record - Shared

Good afternoon,

Sampling the non-contact cooling water today 2/19/2020 indicates pH readings outside of the permit range of 6.5 – 8.0. The Merrimack River intake grab samples were low therefore resulting in effluent grab samples to be outside of the permit range.

- 2/19/2020
 - o Intake pH: 6.1
 - o Effluent pH: 6.1

Please let me know if you have any questions.

Thank you,

Sabre Strout

EHS & Security Coordinator



Nylon Corporation of America

333 Sundial Avenue

Office: (603) 627-5150 Ext. 318

Mobile: (603) 397-7010

Email: sstrout@nycoa.com